

2009 Consumer Confidence Report

Water System Name: Kings Mountain Park Water Company Report Date: Feb. 1, 2010

We test the drinking water quality for many constituents as required by State and Federal Regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2008.

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo ó hable con alguien que lo entienda bien.

Type of water source(s) in use: Surface Water

Name & location of source(s): Purisima Creek watershed

Drinking Water Source Assessment information: See attached copy of the source water assessment (SWA) summary page that is attached.

Time and place of regularly scheduled board meetings for public participation: Every third Tuesday of the month at 7:30 pm at board members home.

For more information, contact: Werner Glinka, President Phone: 650.851.5909

TERMS USED IN THIS REPORT:

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): The level of a disinfectant added for water treatment that may not be exceeded at the consumer's tap.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a disinfectant added for water treatment below which there is no known or expected risk to health. MRDLGs are set by the U.S. Environmental Protection Agency.

Primary Drinking Water Standards (PDWS): MCLs or MRDLs for contaminants that affect health along with their monitoring and reporting requirements, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of the drinking water. Contaminants with SDWSs do not affect the health at the MCL levels.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Variations and Exemptions: Department permission to exceed an MCL or not comply with a treatment technique under certain conditions.

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter (ug/L)

ppt: parts per trillion or nanograms per liter (ng/L)

pCi/L: picocuries per liter (a measure of radiation)

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally-occurring

minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Contaminants that may be present in source water include:

- *Microbial contaminants*, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- *Inorganic contaminants*, such as salts and metals, that can be naturally-occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- *Pesticides and herbicides*, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- *Organic chemical contaminants*, including synthetic and volatile organic chemicals, that are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural application, and septic systems.
- *Radioactive contaminants*, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, USEPA and the state Department of Health Services (Department) prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. Department regulations also establish limits for contaminants in bottled water that must provide the same protection for public health.

Tables 1, 2, 3, 4, and 5 list all of the drinking water contaminants that were detected during the most recent sampling for the constituent. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The Department allows us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

TABLE 1 - SAMPLING RESULTS SHOWING THE DETECTION OF COLIFORM BACTERIA

Microbiological Contaminants (to be completed only if there was a detection of bacteria)	Highest No. of detections	No. of months in violation	MCL	MCLG	Typical Source of Bacteria
Total Coliform Bacteria	0	0	More than 1 sample in a month with a detection	0	Naturally present in the environment
Fecal Coliform or <i>E. coli</i>	0	0	A routine sample and a repeat sample detect total coliform and either sample also detects fecal coliform or <i>E. coli</i>	0	Human and animal fecal waste

TABLE 2 - SAMPLING RESULTS SHOWING THE DETECTION OF LEAD AND COPPER

Lead and Copper (to be completed only if there was a detection of lead or copper in the last sample set)	No. of samples collected	90 th percentile level detected	No. sites exceeding AL	AL	PHG	Typical Source of Contaminant
Lead (ppb)	5		0	15	2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	5		0	1.3	0.17	Internal corrosion of household water plumbing systems; erosion of natural deposits; leaching from wood preservatives

TABLE 3 - SAMPLING RESULTS FOR SODIUM AND HARDNESS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	2/18/03	17 ppm		none	None	Generally found in ground & surface water
Hardness (ppm)	2/18/03	240 ppm		none	None	Generally found in ground & surface water

**Any violation of an MCL or AL is asterisked. Additional information regarding the violation is provided later in this report.*

TABLE 4 - DETECTION OF CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Barium	8/28/08	120 ppb		1000 ppb		Erosion from natural deposits
Nickel	8/28/08	4.9 ppb		100 ppb		Erosion from natural deposits
Combined Radium	Composite	.879 pCi/l		5 pCi/l		Erosion from natural deposits
Flouride	8/28/08	0.31 ppm		2.0 ppm		Erosion from natural deposits
Cadmium	8/28/08	0.26 ppb		5 ppb		Erosion from natural deposits. Internal corrosion of galvanized pipes.
Nitrite (as Nitrogen N)	8/28/08	0.24 ppm		1.0 ppm		Runoff and leaching from fertilizer use. Leaching from septic tanks. Erosion from natural deposits.
Nitrate (as nitrate NO3)	8/28/08	.87 ppm		45 ppm		Erosion from natural deposits
Haloacetic acids (HAA5)	8/24/09	15 ppb		60 ppb		By-product of drinking water chlorination
TTHM (Total trihalomethane)	8/24/09	55 ppb		80 ppb		By-product of drinking water chlorination
Aluminum	8/28/08	15 ppb		1 ppm		Erosion from natural deposits

TABLE 5 - DETECTION OF CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant

TABLE 6 - DETECTION OF UNREGULATED CONTAMINANTS

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Notification Level	Health Effects Language

*Any violation of an MCL, MRDL, or TT is asterisked. Additional information regarding the violation is provided later in this report.

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More

information about contaminants and potential health effects can be obtained by calling the USEPA’s Safe Drinking Water Hotline (1-800-426-4791).

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Summary Information for Contaminants Exceeding an MCL, MRDL, or AL, or a Violation of Any Treatment Technique or Monitoring and Reporting Requirement

For Systems Providing Surface Water as a Source Of Drinking Water:

(Refer to page 1, “Type of water source in use” to see if your source of water is surface water or groundwater)

TABLE 7 - SAMPLING RESULTS SHOWING TREATMENT OF SURFACE WATER SOURCES	
<i>Treatment Technique</i> ^(a) (Type of approved filtration technology used)	Rosedale Filter
Turbidity Performance Standards ^(b) (that must be met through the water treatment process)	<u>Turbidity of the filtered water must:</u> 1 – Be less than or equal to 0.2 NTU in 95% of measurements in a month. 2 – Not exceed 0.5 NTU for more than eight consecutive hours. 3 – Not exceed 1.0 NTU at any time.
Lowest monthly percentage of samples that met Turbidity Performance Standard No. 1.	100
Highest single turbidity measurement during the year	0.034
Number of violations of any surface water treatment requirements	

(a) A required process intended to reduce the level of a contaminant in drinking water.

(b) Turbidity (measured in NTU) is a measurement of the cloudiness of water and is a good indicator of water quality and filtration performance. Turbidity results which meet performance standards are considered to be in compliance with filtration requirements.

Summary Information for Surface Water Treatment

Water is initially filtered through a Rosedale filter bag. The water is then processed through Homespring untrafiltration units which meets current federal requirements for removal of *Cryptosporidium*. Chlorine solution is then injected and water is routed to a storage tank to ensure adequate chlorine contact time. Daily measurements of Chlorine and turbidity are taken. Automated systems prevent water with elevated turbidity to enter system. Automated chlorine monitors system to ensure that chlorine is within a specific operating range. Weekly residual chlorine tests are performed at first point of use to ensure adequate chlorine in system.